



Notice of Revised Pedernales Electric Cooperative Specifications Posted September 6, 2022

Residential and Commercial 320 Amp Meter Loop Specifications

- Various Pages
 - Various minor design updates and minor text edits.
 - Added connection detail and made revisions to reinforce requirements for main disconnects on panels and bypass handles on each 320 A socket.
- Page 3
 - Clarified notes for pipe nipple connections. Added Note 3 under *Pipe Nipple Connections* to allow Schedule 40 only if ground wire is installed as shown on Page 8.
- Page 8
 - Added detail to show ground wire connections between the panels and the meter socket.

Underground Installation Specifications

- 530-034: 3Ø Transformer Pad 2000-3000 kVA
 - Added the following note: *Ground in front of pad-mounted equipment shall not have a slope of more than 6" in 10'.*

Note: *The summaries listed here and in previous notices primarily include revisions considered technically significant to these specifications. Edits considered technically insignificant may not be listed.*