



Notice: Revised Pedernales Electric Cooperative Specifications

August 12, 2024

Underground Installation Specifications

- Specification 520-020: *52" Pad for 1Ø Transformer with VFI, Small Sectionalizing Enclosure*
 - Added specifications for optional 2" temporary service conduit
- Specification 520-030: *72" Pad for 1Ø Transformer with VFI, Small Sectionalizing Enclosure*
 - Added specifications for optional 2" temporary service conduit
- Specification 550-021: *Tap Box*
 - Added additional tap box model for Hubbell/CMC (LWTE22-750LI)
 - Added ANSI C119.4 requirement
 - Added the following text providing an option for members/developers to provide alternative tap boxes not specified:
 - **Tap boxes meeting all required specifications that are produced by manufacturers and/or consist of part numbers not listed above may be provided by the member/developer with PEC approval.*

Note: *Summaries listed here and in previous notices primarily include revisions considered technically significant to the referenced specifications. Edits considered technically insignificant may not be listed.*