



Notice: Revised Pedernales Electric Cooperative Specifications

September 27, 2024

Residential and Commercial 320-Amp Meter Loop Specifications

- Page 8: *Typical URD 320A Free-standing Rack*
 - Revised #6 *COPPER MIN.* to #2 *COPPER MIN.* on note near bottom of meter socket

Note: *Summaries listed here and in previous notices primarily include revisions considered technically significant to the referenced specifications. Edits considered technically insignificant may not be listed.*