



## **Notice: Revised Pedernales Electric Cooperative Specifications**

**Posted January 27, 2025**

### **Underground Installation Specifications**

- Specification 500-100: *Developer/Member/PEC Supplied Material*
  - Removed Note 16, Meter sockets (PEC will provide pedestal-mounted sockets only). This note was redundant to Note 14.
- Specification 500-103: *Approved Manufacturers and Distributors*
  - Revised *Secondary Enclosures* to *Secondary/Sectionalizing Enclosures* in *Type of Material* column for four manufacturers to reflect these manufacturers' production of both types of materials.
  - Removed sectionalizing enclosure manufacturer AZZ
  - Added sectionalizing enclosure manufacturer ABB.
  - Added tap box manufacturers Givco, Milbank, and Hubbell Power Systems (CMC)
- Specification 510-009: *Typical Trench, Pad, & Meter Pedestal Notes*
  - Revised title from *Typical Trench, Pad, & Meter Pedestal Notes* to *Typical Pad, Trench, Conduit, & Meter Pedestal Notes*
- Equipment pad specifications
  - Specifications 520-010, 530-030, & 530-032: Modernized drawings and updated notational reference to 510-009 to include *Page 1*.
  - Specifications 530-020, 530-022, 530-024, & 530-026: Revised manufacturer name *Barfield-Hubbell* to *Hubbell-CMC*
  - Specifications 530-020 & 530-024: Revised manufacturer name *Malton-ABB* to *ABB*
- Specification 550-021: *Tap Box*
  - Revised Hubbell/CMC 500 kcmil part number; changed from a 19-position tap box to a 21-position tap box.
- Specifications 560-050, 560-051, and 560-052: *Secondary Riser with Standoffs, Secondary Riser with Standoffs to a Meter Rack; 600-Volt Underground Service from Overhead Transformer*
  - Revised manufacturer name *Barfield* to *Hubbell-CMC*

**Note:** Summaries listed here and in previous notices primarily include revisions considered technically significant to the referenced specifications. Edits considered technically insignificant may not be listed.