



Notice: Revised Pedernales Electric Cooperative Specifications

Posted February 12, 2025

Residential & Commercial 100-Amp & 200-Amp Meter Loop Specifications

- Page 2, Note 14
 - Added the following note and moved the previous notes 14 and 15 down: *Service from transformer to meter shall not exceed 150' unless prior written approval is obtained from PEC.*
- Page 3, Meter Sockets and Pedestals section.
 - Added the following sentence: *If a reducer is required at a knockout, the reducer shall abut to the socket enclosure.*

Residential & Commercial 320-Amp Meter Loop Specifications

- Page 2, Note 14
 - Added the following note and moved the previous notes 14 and 15 down: *Service from transformer to meter shall not exceed 150' unless prior written approval is obtained from PEC.*

Note: *Summaries listed here and in previous notices primarily include revisions considered technically significant to the referenced specifications. Edits considered technically insignificant may not be listed.*