



Notice: Revised Pedernales Electric Cooperative Specifications

Posted June 4, 2025

Underground Installation Specifications

- Specification 560-050: *Single-Phase Riser with Standoffs*
 - Revised Note 2 in *Notes to Members* to clarify that PEC shall supply standoff brackets, straps, and secondary wire.
 - Removed secondary enclosure and related annotation.
 - Removed materials table listing standoff brackets and strap kits.
 - Revised title from *Secondary Riser with Standoffs* to *Single-Phase Riser with Standoffs*.
- Specification 560-051: *Single-Phase Riser with Standoffs to a Meter Rack*
 - Revised Note 2 in *Notes to Members* to clarify that PEC shall supply standoff brackets, straps, and secondary wire.
 - Removed secondary enclosure and related annotation.
 - Removed materials table listing standoff brackets and strap kits.
 - Revised title from *Secondary Riser with Standoffs to a Meter Rack* to *Single-Phase Riser with Standoffs to a Meter Rack*.
- Specification 560-052: *600-Volt Underground Service from Overhead Transformer*
 - Revised Note 2 in *Notes to Members* to clarify that PEC shall supply standoff brackets, straps, and secondary wire.
 - Removed secondary enclosure and related annotation.
 - Removed materials table listing standoff brackets and strap kits.

Note: Summaries listed here and in previous notices primarily include revisions considered technically significant to the referenced specifications. Edits considered technically insignificant may not be listed.